

**CITY AND INDUSTRIAL DEVELOPMENT CORPORATION OF MAHARASHTRA LIMITED**

(CIN - U99999 MH 1970 SGC - 014574)

**REGD. OFFICE:**

"NIRMAL", 2nd Floor, Nariman Point,  
Mumbai - 400 021.

PHONE : 00-91-22-6650 0900

FAX : 00-91-22-2202 2509

**HEAD OFFICE:**

CIDCO Bhavan, CBD Belapur,  
Navi Mumbai - 400 614.

PHONE: 00-91-22-6791 8100

FAX : 00-91-22-6791 8166

Ref. No. CIDCO/FIRE/HQ/2025/123


Date: 23/06/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M/S. JANARDAN BHAGAT SHIKSHAN PRASARAK SANSTHA at Plot no.01, Sector-12, Ulwe, Navi Mumbai comprised of Ground + 4 Upper Floors owned / occupied by M/s. RAMSHETH THAKUR PUBLIC SCHOOL have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officer concerned of Fire Service on 21/06/2025 in the presence of Principal Shri Kiran Kumar Suthar & M/s. Om Sai Fire Protection, Fire License Agency and that the building/premises is fit for occupancy up to Class XII th. As the party / school had submitted the affidavit cum declaration about the existing fix fire protection system will be kept in good working condition for the year 2025-2026 i.e. from 01/07/2025 to 30/06/2026. Hence the fire safety certificate is issued by this section for the period of one year i.e till 30/06/2026 in accordance with rule and subject to compliance of specific conditions as appended :-

- 1) Inbuilt Fire Fighting System Should be kept in good working condition all the time.
- 2) As per the Maharashtra Fire Prevention & Life Safety Act, 2006 it is statutory requirement to check the in-built fire protection system from licensing agency twice in a year (in the month of January & July) & produce the Form 'B' certificate to this department
- 3) School management shall train all staff members to operate the Fire Extinguisher.

Issued on 23/06/2025 at Navi Mumbai by

Signature with Seal : 

Name : Vijay S. Rane

Designation : Chief Fire Officer

Name &amp; Address of Department / Office: CIDCO FIRE SERVICE

To,

The Principal,

M/s. Ram Sheth Thakur Public School,

Plot no.01, Sector-12

Ulwe, Navi Mumbai 410206.